कार्यालय अधिशासी अभियन्ता, षष्टम शाखा, उत्तर प्रदेश जल निगम, बरेली।

जल विश्लेषण आख्या

स्थान का नाम/लोकेशन	ग्राम/मजरा	ब्लाक	तहसील	स्त्रोत का नाम	रंग	गंध	TDS (PPM) 500-2000	PH 6.5-8.5	रसायनिक परीक्षण										
									Cloride 250-1000	Floride 1.0-1.5	Hardness 300-600	Sulphate 200-400	Iron 0.3-1.0	Nitrate 45-45	Nitrite nil	Alkanity 300-600	Residual chlorine 0.2-0.5	जीवाणु Nil	
2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	2
राजश्री इन्स्टीट्यूट ऑफ मैनेजमेन्ट एन्ड टेक्नालोजी (RIMT)	लेमेड़न	नवाब गंज 1	नवाब गंज 1	समर सबुल पम्प	-	-	400	7.75	10	0.75	180	19.2	0.2	0.4430	Nil	180	-	Nil	

PANKAJ KUMAR SHARMA

Digitally signed by PANKAJ KUMAR SHARMA
DN: c=IN, o=PERSONAL, pseudonym=56e7bf2a69e74eeeb066c9b16065c232, 2.5.4.20=f913dbae5c80ebdd8cf5fa6696a03708dd90e5495373ccd7c4fada6cf71280e1, postalCode=243006, st=Uttar Pradesh, serialNumber=d3626584ce5ad271d303e7fbe902f773060d5734eee66f6ea076e4dddf976809, cn=PANKAJ KUMAR SHARMA
Date: 2024.03.12 15:16:37 +05'30'

18-6-10

Lab Technician

Junior Engineer (Lab)

Assistant Engineer

Executive E